

2016

Appendix B - Assessment of the potential for solar PV farms in Gwynedd and Ynys Môn

Joint Local Development Plan Anglesey & Gwynedd

LUC

Assessment of the potential for solar PV farms in Gwynedd and Ynys Môn

Final Report Prepared by LUC in association with Carbon Smart July 2016

Project Title: Assessment of the potential for solar PV farms in Gwynedd and Ynys Môn

Client: Gwynedd and Anglesey Joint Planning Policy Unit

Version	Date	Version Details	Prepared by	Checked by	Approved by
0.1	08/06/2016	First draft for discussion	Maria Grant	Diana Manson	Sarah Young
0.2	30/06/2016	Draft Report	Maria Grant Diana Manson Helen Troup	Diana Manson	Sarah Young
0.3	05/07/2016	Final report	Maria Grant Diana Manson Helen Troup	Diana Manson	Sarah Young

Planning & EIA LUC BRISTOL 12th Floor Colston Tower Design Landscape Planning Colston Street Bristol Landscape Management BS1 4XE Ecology T +44 (0)117 929 1997 Mapping & Visualisation bristol@landuse.co.uk



Land Use Consultants Ltd Registered in England Registered number: 2549296 egistered Office: 43 Chalton Street London NW1 1JD FS 566056 EMS 566057 LUC uses 100% recycled paper

ISO 14001

Offices also in London Glasgow Edinburgh

Contents

1 Introduction

Introduction Context Report Structure

2 Methodology

Technical and planning constraints Technical and financial constraints Landscape Sensitivity and Capacity Review

3 Findings

Wider constraints and higher level infrastructure Prioritising the suitable areas

Appendix 1

DNO Infrastructure

Appendix 2

Landscape Sensitivity and Capacity Review

Appendix 3

Full Assessment Results

Tables

i

5

13

Table 2.1: Criteria used in the assessment of suitability Table 2.2 Additional criteria considered but not included as constraints Table 2.3: Further constraints applied Table 2.4 Technical and financial constraints Table 3.1 Top rated Opportunity Areas Table 3.2 Prioritisation of remaining Opportunity Areas

Maps

Map 2.1: Study area
Map 2.2: Built up areas and infrastructure
Map 2.3: Natural features
Map 2.4: Biodiversity and geodiversity
Map 2.5: Heritage and landscape
Map 2.6: Slope and orientation
Map 2.7: Agricultural Land Classification
Map 2.8: Further considerations
Map 2.9: DNO Infrastructure
Map 2.10: Landscape Sensitivity
Map 3.1: Opportunity Areas
Map 3.2: Opportunity Areas following application of technical, financial and landscape sensitivity constraints
Map 3.3: Top rated and prioritised Opportunity Areas

1 Introduction

Introduction

- 1.1 LUC and Carbon Smart were commissioned to undertake an assessment of the potential suitability of land within Gwynedd planning area and Anglesey for large scale solar PV development.
- 1.2 The key objectives of the study were to:
 - Assess the potential and identify areas of search for Solar PV farms (above 0.5MW) within the Plan area (taking account of a series of land use, environmental, technical and financial constraints and opportunities).
 - Clearly set out the assumptions upon which the study is based, providing a robust, transparent and defensible evidence base that will withstand scrutiny.
- 1.3 Achievement of these objectives will enable the Joint Planning Policy Unit (JPPU) to allocate the most suitable and viable potential areas for solar PV farm development within the Local Development Plan, whilst protecting locations valued for their environmental, landscape or heritage importance.

Context

Solar Industry

1.4 The solar photovoltaic (PV) market in the UK has grown from virtually zero in 2010 to an estimated 9.2GW of installed capacity by 2016 (enough to power 2.2 million British homes)¹.

- 1.5 In April 2016, a milestone was passed when it was revealed that, for the first time, the sun provided more UK electricity from photovoltaic panels than from coal-fired plants over a full 24-hour period. Just under 30 gigawatt hours or 4% of national demand was met by solar.
- 1.6 This rapid growth, occurring as it has against a backdrop of economic austerity, propelled the UK into the top ten global markets for solar PV. The published Part 2 of the UK Solar PV Strategy (April 2014) includes a non-binding target to install up to 20GW of solar capacity early in the next decade. Whilst the focus of the Strategy is arguably on roof-top solar projects rather than larger scale ground-mounted projects, the latter is likely to have a continued role to play. Appropriate siting and design and will continue to be key.
- 1.7 The success of solar to date has been driven by a combination of falling product prices solar panels are 80% cheaper now than they were five years ago but also by subsidies (the Feed in Tariff (FiT) and Renewables Obligation (RO)). Over the last year both the RO and FiT support mechanisms have been either removed or wound dramatically further down with the government arguing the industry should largely be fending for itself while bill payers should be spared unnecessary cost. The RO has been replaced by Contracts for Difference (CfD's) but several schemes that secured strike prices under this new regime have not been progressed due to viability issues.
- 1.8 Despite these setbacks, a spokesperson for the Department of Energy and Climate Change (DECC) said:

"Solar, nuclear, offshore wind and shale gas all have an important part to play in our future energy mix – this diversity is essential so we can deliver secure, affordable and clean energy for future generations."

¹ Source: DECC.

"The costs of solar continue to fall and we are working to create a sustainable industry that delivers without subsidy."

1.9 The economic and financial constraints to solar PV development are considered in the methodology section (Section 2) of this report.

National policy context

- 1.10 Climate change and energy security are stated to be key priorities for the UK Government. On the 30th June 2016, Ministers laid regulations before Parliament for the 'fifth carbon budget' which governs reductions in emissions for the period 2028-2032. The Government has adopted targets that will require a 57% reduction in greenhouse gas emissions by 2030. The reductions are aimed at helping the UK reach the legally binding target of an 80% reduction in greenhouse gas emissions by 2050, (using the emissions in 1990 as a baseline).
- 1.11 In 2007, European Union (EU) leaders agreed to adopt a binding target requiring 20% of the EU's energy (electricity, heat and transport) to come from renewable energy sources by 2020. The UK signed up to the EU Renewable Energy Directive (formally agreed in April 2009) and agreed to legally binding targets to generate 15% of all our energy (electricity, transport and heat) from renewable sources by 2020. The UK Renewable Energy Strategy sets out the path for the UK to meet this target and states that 30% of electricity will need to come from renewable source by 2020.
- 1.12 The Welsh Government has set out an ambition to reduce CO₂ emissions in Wales and to produce more of their energy from renewable and low carbon energy sources, including solar. The energy policy, Energy Wales: A Low Carbon Transition (2012), sets out how Wales will move from fossil fuel based energy generation to utilise a wider mix of energy sources, which are mainly renewable or low in carbon. The Climate Change Strategy for Wales (2010) also sets a target to reduce its emissions of greenhouses gases by 3% per year from 2011 from areas of devolved competence.

- 1.13 The energy and environment sector is considered to be a key component underpinning the drive for 'Economic renewal: a new direction.' It identifies the two main opportunities for creating jobs for a sustainable economy as delivering resource efficiency; and driving forward the low carbon, low waste agenda. It hoped that with targeted intervention, Wales can gain competitive advantages and benefit from the markets within this sector. It is estimated that there could be £50 billion of investments in low carbon electricity production in Wales over the next 10 to 15 years.
- 1.14 Planning Policy Wales (PPW) (Edition 8, Jan 2016) and supporting Technical Advice Notes (TAN 12 and TAN 8) and practice guidance, set out a number of areas of evidence gathering and policy making for renewable and low carbon energy generation that local authorities are expected to consider when developing their Local Development Plan's. These requirements include planning for renewable and low carbon energy (chapter 12.8 in PPW).
- 1.15 Section 12.8.2 of PPW specifically mentions using a Planning for Renewable and Low Carbon Energy - A Toolkit for Planners Toolkit (2015), and states:

Planning policy at all levels should facilitate delivery of both the ambition set out in Energy Wales: A Low Carbon Transition and UK and European targets on renewable energy. The Renewable Energy Directive contains specific obligations to provide guidance to facilitate effective consideration of renewable energy sources,.....The issues at the heart of these duties are an established focus of planning policy in Wales, and in this context both local planning authorities and developers should have regard in particular to the guidance contained in Technical Advice Note 8: Planning for Renewable Energy and Planning for Renewable Energy – A Toolkit for Planners.

1.16 The Welsh Government's key requirements and expectations for local authority plan making for these aspects as set out in PPW are as follows:

1.17 Renewable and Low Carbon Energy (PPW Chapter 12.9.2 and 12.9.3) state:

Local planning authorities should guide appropriate renewable and low carbon energy development by undertaking an assessment of the potential of all renewable energy resources and renewable and low carbon energy opportunities within their area and include appropriate policies in development plans. Local planning authorities are encouraged to work collaboratively in order to gather evidence on a sub-regional basis wherever possible.

In undertaking such assessments local planning authorities should establish an evidence base which:

- takes into account the contribution that can be made by their local area towards carbon emission reduction and renewable and low carbon energy production;
- recognises that approaches for the deployment of renewable and low carbon energy technologies will vary;
- identifies the accessible deliverable renewable energy resource potential (including heat) for their area and considers the likely utilisation of this resource over the plan period;
- takes into account the environmental, social and economic impacts and opportunities from renewable and low carbon energy development;
- takes into account the cumulative effects of renewable and low carbon energy development;
- takes into account the likely mechanisms for determining applications for sites based on their potential and actual output; and
- takes into account issues associated with grid connection and the transportation network.
- 1.18 In December 2015, The Minister for Natural Resources in Wales wrote to Planning Lead Members to inform them of the Changes to Section 12 of the PPW. The letter also urged authorities to formulate policies (including allocations for areas of search) for local authority scale renewable energy schemes. It stated that:

"The designation of such areas would show leadership at the local level; give certainty to the renewable energy industry in making investment decisions; and, through the LDP consultation process, would give communities a say as to where renewable energy developments should be located. By designating these areas, developments can be guided to the most appropriate locations.

1.19 It went on to state that:

"The Welsh Government has recently published a revised version of the Renewable Energy Toolkit for Planners. This toolkit has been updated and includes a new section for local planning authorities (LPAs) to assess the potential for solar farm developments in their areas. This methodology, coupled with the extensive landscape assessments already produced as part of the LDP evidence base, can be used to identify in Development Plans policies for renewable energy developments. These areas can be informed by local priorities for renewable energy and the deliverability of schemes in consultation with landowners and the renewable energy industry whom I also expect to engage in the process to identify the most appropriate sites."

"It is imperative that the planning system identifies and protects areas with renewable energy generation potential for the long term, irrespective of any short term decisions on financial support and regulatory regimes which are being taken by the UK Government."

- 1.20 The revised toolkit provides advice on how the translation between evidence and policies should be achieved and the Minister has stated that particular attention will be given to this issue when LDPs are passed to the Welsh Government for comment.
- 1.21 A further Ministerial letter was sent to Planning Lead Members in March 2016, reiterating the importance the Welsh Assembly Government place on the transition to a low carbon economy. The letter restated the need for local authorities to be more proactive in developing positive local planning policies towards renewable energy developments through strategies and spatial allocations.

Local policy context

- 1.22 The Anglesey Energy Island Programme aims to make Anglesey a driving force behind energy research and development, generating and servicing, bringing economic and social benefits to the Island and the surrounding area. Gwynedd Werdd has studied the potential for producing renewable energy by making the most of the natural resources throughout the county. Gwynedd Werdd alongside Anglesey Energy Island is also working with local colleges to ensure that training needed to make the most of renewable energy is available
- 1.23 The Gwynedd and Anglesey Joint Local Development Plan (JLDP) details numerous polices that seek to promote renewable energy production, whilst also giving weight to the need to ensure that these developments are sensitively sited and designed.
- 1.24 Relevant objectives and policies in the JLDP include, but are not limited to:
 - SO6: Minimise, adapt and mitigate the impacts of climate change (including promoting renewable and low carbon energy production within the area)
 - Policy PS6: Alleviating and adapting to the effects of climate change.
 - Policy PS7: Renewable energy technology.
 - Policy ADN2: Other renewable energy technologies.
 - SO16: Protect, enhance and manage the natural and heritage assets of the Plan area, including its natural resources, wildlife habitats, and its landscape character and historic environment.
 - Policy PS16: Conserving and enhancing the natural environment.
 - Policy AMG5: Protecting sites of regional or local significance.
 - Policy PS17: Preserving and enhancing heritage assets.

1.25 This study and its outputs will provide the JPPU with a robust evidence base to underpin the identification of potential solar PV development areas within the Local Development Plan.

Report Structure

- 1.26 The reminder of this report is structured as follows:
 - **Chapter 2**: sets out the methodology used to undertake the assessment.
 - Chapter 3: presents the study findings.
 - **Appendix 1**: provides information on the Distributed Network Operator (DNO) Infrastructure.
 - **Appendix 2:** Summarises the findings from the Landscape Sensitivity and Capacity Review.
 - Appendix 3: sets out the full assessment results.

2 Methodology

- 2.1 An assessment was undertaken of the land that could be suitable for solar PV development. This type of assessment is undertaken using Geographic Information Systems (GIS) and considers a range of opportunities and constraints that relate to solar PV development. This is a desk-based assessment and no verification has been undertaken in the field.
- 2.2 The study area consists of the Gwynedd planning area (i.e. excludes Snowdonia National Park) and Anglesey as shown in Map 2.1.
- 2.3 The methodology is based on Sheet K from the Welsh Government Practice Guidance: Planning for Renewable and Low Carbon Energy – A Toolkit for Planners (September 2015). This sets out guidance on how local authorities should assess the potential for solar PV within their area.

Technical and planning constraints

- 2.4 Table 2.1 lists the criteria used in this assessment, the justification for their inclusion, and the data sources used to undertake the assessment. Table 2.2 lists the criteria that were considered for inclusion, but discounted. It also records the reason for excluding them from the assessment.
- 2.5 Each of the layers detailed in **Table 2.1** were collated in an ESRI geodatabase. These layers were added to a map and organised according to topics.

- 2.6 The layers were combined in GIS using a 'Union' in order to create a single layer of 'constrained' land that was unsuitable for solar PV Farm projects. Using GIS, these unsuitable areas were subtracted from the area of interest boundary in order to identify the land that remained once the constraints had been applied.
- 2.7 The steps followed for this first stage of the study are as follows:
 - Map built-up areas and locations of other infrastructure.
 - High level assessment of opportunities within built-up areas (this step concluded that there were no areas of opportunity within built-up areas)
 - Map environmental and heritage constraints.
 - Map areas of unsuitable slope and aspect.
 - Map areas of unsuitable Agricultural Land Classification.
- 2.8 The above steps deviate slightly from the order set out in Sheet K as it was considered beneficial to remove as many unsuitable areas as possible before considering the potential installed capacity.
- 2.9 Following the application of the steps outlined in paragraph 2.7, there were still a considerable number of potential Opportunity Areas for solar PV. The toolkit is clear in terms of the assessment needing to result in a manageable number of Opportunity Areas for consideration. It was therefore considered appropriate to apply additional constraints to reduce the overall land area being considered.
- 2.10 In discussion with the client team, the additional constraints set out in **Table 2.3** were removed.

Parameter	Assumption	Data source	Justification and notes
Built up areas (See Map 2.2)	 The vast majority of locations within built up areas will have no potential. Areas allocated for housing or employment should be considered constrained. 	 Development boundaries Clusters Housing allocations with permission Housing allocation without permission Employment areas 	 The location of built up areas will significantly constrain any deployment of large-scale stand-alone PV farms. The Welsh Government (WG) method suggests the use of OS Strategi data to identify these areas. A thorough review of the Strategi dataset for this area showed that the dataset was not fit for purpose in this location (boundaries were too crude and not detailed enough). Other datasets were tested, but it was agreed that the Development Boundaries and Clusters that are used within the JLDP to identify towns and villages would be the best to use. The client team identified site allocations for housing and employment as constraints for this purpose.
Infrastructure (See Map 2.2)	 Motorways, A Roads, B Roads (with a buffer to approximate the footprint) Railway lines (with a buffer to approximate the footprint) 	Ordnance Survey VectorMap District	 The WG method suggests the use of OS Strategi data for this constraint. This data is linear (and does not have a footprint) and is 1:250 000 scale. There are other Ordnance Survey products available that are higher resolution and considered better for this assessment. OS VectorMap District linear data has been used with the following widths in order to approximate a footprint (and allow an area to be subtracted): Dual carriageways (20m) Single carriageways (10m) Railway tracks (15m)

Table 2.1: Criteria used in the assessment of suitability

Parameter	Assumption	Data source	Justification and notes
Natural features (See Map 2.3)	 Woodland Areas Lakes and Rivers Flood warning areas 	 Ordnance Survey VectorMap District WG Flood Warning Areas C1 and C2 	 The WG method suggests the use of OS Strategi data for this constraint. There are other Ordnance Survey products available that are higher resolution and considered better for this assessment – namely OS VectorMap District which has a higher resolution. Additionally, the use of this dataset for lakes and rivers removes the need to make an assumption about river width (as the OS Strategi dataset for rivers is linear and a footprint would need to be assumed). On the advice of the JPPU, Areas C1 and C2 are considered to be the equivalent of flood warning areas as these are assumed to be constrained on the basis that these are the areas used to indicate that flooding issues should be considered an integral part of decision making.
Biodiversity/geodiversity (See Map 2.4)	 Special Protection Areas (SPA) Special Area of Conservation (SAC) Candidate Special Area of Conservation (cSAC) RAMSAR Sites National Nature Reserves (NNR) Local Nature Reserves (LNR) Site of Special Scientific Interest (SSSI) Marine Nature Reserves (MNR) (not relevant) 	 Natural Resources Wales Joint Nature Conservation Committee 	 The WG method assumes that there is no potential for large-scale solar PV farm developments within these designated areas.
Heritage (See Map 2.5)	 Scheduled Monuments Conservation Areas World Heritage Sites 	CADWJPPU	 The WG method assumes that there is no potential for large-scale solar PV farm developments within Scheduled Monuments. In agreement with the JPPU, World Heritage Sites and Conservation Areas

Parameter	Assumption	Data source	Justification and notes
			were additionally included as areas of constraint.
Landscape	Areas of Outstanding Natural Beauty	• NRW	 The WG method assumes that there is no potential for large-scale solar PV farm developments within AONBs.
(See Map 2.5)			
Slope and orientation (See Map 2.6)	 Inclinations 0-3 degrees: all orientations suitable for development 	OS Terrain 50	The assumptions are based on the WG method.
(See Map 2.0)	 Inclinations 3-15 degrees: only south-west to south east facing slopes suitable for development 		
	Inclinations 15 degrees+: constrained		
Agricultural Land Classification	Agricultural Land Classification Grades 1, 2	ALC Provisional data	Large-scale ground mounted solar PV should be located on less productive
(See Map 2.7)	and 3a are constrained	WG Best and Most Versatile (BMV) dataset	agricultural land or previously developed land.
			The ALC Provisional data does not distinguish between grades 3a and 3b.
			• Through consultation with WG, we have assumed that Grades 1, 2 and 3 from the provisional dataset are constrained except in locations where the WG has previously identified the area to be non-BMV.

Table 2.2 Additional criteria considered but not included as constraints

Consideration	Reason for not including as a constraint	
Overhead power lines (400kV) and preferred routeing corridor	 Overhead powerlines may cause shading. However, given the movement of the sun throughout the day, it would be difficult to approximate an area of influence for this. 	
	• The relationship of areas of potential and the preferred routeing corridor for the new National Grid Overhead line will be considered at a later stage.	
RSPB Reserves	• It is assumed that the most sensitive bird areas will be protected by other biodiversity designations. These	

Consideration	Reason for not including as a constraint
	could be considered at a later stage if prioritising the available land.

Table 2.3: Further constraints applied

Parameter	Assumption	Data source	Justification and notes
Landscape (See Map 2.8)	Special Landscape Areas	• JPPU	 Special Landscape Areas are a non-statutory designation which offers additional protection to the landscape. Policy AMG1 in the Deposit Plan (2015) states that 'any development proposal gives consideration to maintaining, enhancing or restoring the recognised character and quality of the areas'. All areas designated as Special Landscape Areas are considered constrained.
Heritage (See Map 2.8)	 Landscapes of Outstanding Historic Interest Registered Parks, Essential Settings and Kitchen Gardens Candidate World Heritage Sites 	 CADW JPPU 	 The importance of Landscapes of Outstanding Historic Interest is identified in policy PS17, which also recognises the importance of protecting the setting of these assets. All of these areas are considered constrained. Draft boundaries for sites being considered as potential World Heritage Sites were
			sense checked against the remaining areas.
Recreation and Access (See Map 2.8)	CROW Dedicated Land	• NRW	• Development of solar PV on Open Access Land is likely to adversely affect the recreational amenity of the area, as fencing is required around these sites for security and safety reasons. All dedicated access land under the Countryside Rights of Way Act is considered constrained.

Technical and financial constraints

- 2.11 The land remaining as a result of the application of these further constraints was still too extensive when compared to the example of 20-30 Opportunity Areas noted in the Toolkit. It was considered appropriate to apply some high level financial and economic viability constraints to remove those areas that would not be economically viable.
- 2.12 Optimal siting of solar panels depends on a range of factors, including the capacity of, and costs associated with, connecting to the grid via the local Distribution Network Operator (DNO). Existing DNO level infrastructure in Anglesey and Gwynedd was mapped, along with its current condition, which is a measure of the likelihood and cost of connection this data was taken from SP Energy Network's Distributed Generation Heat Map².
- 2.13 Using maps of the DNO infrastructure, the Red/Amber/Green (RAG) rating of up to four constraints was captured for each grid-, super- and sub-station within the area of interest. These constraints are:
 - reverse flow;
 - generation capacity;
 - fault level (for the relevant voltage); and
 - wider constraints.
- 2.14 A list of stations considered is included in **Appendix 1**.
- 2.15 For more than three quarters of the stations in question, the "wider constraints" rating is red, however this does not necessarily exclude the location from hosting new generation technologies³.
- 2.16 **Table 2.4** sets out technical and financial constraints used to eliminate unviable land.

Landscape Sensitivity and Capacity Review

- 2.17 Following the application of all of the above constraints, **92 individual Opportunity Areas remained** that were above the required size threshold of 1.2ha (or 3 acres) needed to support developments of 0.5MW or more.
- 2.18 Using the steps set out in the Toolkit, at this stage, there is provision within the method to apply further constraints based on a stricter application of the Agricultural Land Classification constraint or the introduction of LANDMAP information to constrain the areas further.
- 2.19 In consultation with the Welsh Government, it was agreed there was no justification for ruling out land in Agricultural Land Classification Grade 4 (as per the Toolkit example).
- 2.20 Given the availability of landscape sensitivity information directly related to solar PV development, it was considered appropriate to look at the Landscape Sensitivity of each Opportunity Area to rule out any Opportunity Areas that are located in areas with a high landscape sensitivity rating for solar PV developments.
- 2.21 Scores from the Landscape Sensitivity and Capacity Assessment⁴ and its addendum⁵ were used to generate a summary table of the landscape sensitivity of each Landscape Character Area (LCA) – focussing in on the areas that remained after all of the preceding constraints had been removed.
- 2.22 The landscape sensitivity of each LCA is shown in **Map 2.10**. The results of this review are shown in **Appendix 2**.

² <u>http://www.spenergynetworks.co.uk/pages/sp_manweb_heat_maps.asp</u>

³ This rating was correct as of 28/6/16.

⁴ Gillespies (March 2014) *Isle of Anglesey, Gwynedd and Snowdonia National Park: Landscape Sensitivity and Capacity Assessment.* Accessible here:

https://www.gwynedd.llyw.cymru/en/Council/Documents---Council/Strategies-and-policies/Environment-and-planning/Planning-policy/Supporting-documents/Landscape-Sensitivity-and-Capacity-Assessment-(DC.020).pdf

⁵ Gillespies (June 2016) *Field-Scale Solar PV Developments: Gwynedd Addendum to March 2014 Landscape Sensitivity and Capacity Assessment Draft Report.*

- 2.23 Opportunity Areas within Landscape Character Areas assessed as having no capacity for field-scale solar PV development were removed as well as Opportunity Areas within Landscape Character Areas assessed as only having potential for micro-scale solar PV development. Micro-scale is defined in the Landscape Sensitivity Study as developments less than 500kW – which is below the capacity threshold for the purposes of this study.
- 2.24 The results of applying this methodology are set out in the next section, along with the process used to rank/prioritise the remaining Opportunity Areas.

Table 2.4 Technical and financial constraints

Parameter	Assumption	Data source	Justification and notes
Distance to infrastructure (See Map 2.9)	 Consider only those areas within 1km of substations rated green for generation and 11kV faults as viable. 	 SP Energy Networks Solar developer research 	 Solar developers will only consider a site that is within 1km of a substation without any red ratings. Having mapped all the substations within the area of interest, this constraint was applied early in the process to reduce the amount of land identified. Given that infrastructure is being constantly upgraded, we have not ruled out all red-rated infrastructure, but in order to prioritise, we have only considered those substations rated green for generation and 11kV faults.

3 Findings

- 3.1 The results of applying all of the constraints set out in **Table 2.1** and **Table 2.3** are shown in **Map 3.1**. This map shows that at this stage in the method, a significant amount of land was showing as having technical potential for solar PV farm development. The total amount when summed amounted to almost 26 000 hectares – or a little over 15% of the entire area of search.
- 3.2 The application of the technical and financial constraint listed in **Table 2.4** drastically reduced the land area. The resultant land area of 1,818 hectares (a little over 1% of the entire search area) was split into 92 discrete parcels of land or Opportunity Areas.
- 3.3 Taking the results of the Landscape Sensitivity and Capacity Study into consideration, 45 of these Opportunity Areas were ruled out on the basis that they either had no capacity (too sensitive) or only had capacity for micro-scale developments (less than 0.5MW). This left **47 Opportunity Areas** requiring further examination using the factors detailed below. **Map 3.2** shows the Opportunity Areas that were ruled out on the basis of their sensitivity and the remaining Opportunity Areas that underwent further analysis.

Wider constraints and higher level infrastructure

3.4 In order to rank the list of Opportunity Areas, capacity in the higher level infrastructure (superstations) was reviewed. Grid and super stations in Anglesey are all critically constrained. The National Grid is delivering upgrades to these connections, with an expected capacity release date of 2019-2025. While this is within the timeframe for the Plan, new generation projects on that infrastructure are already contracted, with over 100MW in the

pipeline, which would take priority over any new applications on Opportunity Areas identified in this study. All Anglesey Opportunity Areas are therefore deprioritised, with a view to potential future connection at a later date. The higher level infrastructure in Powys and the south of Gwynedd is also critically constrained by the Swansea North interconnection; these substations are also therefore excluded.

Cascade higher level infrastructure rating to "daughter" infrastructure

- 3.5 The two remaining Super Stations (Connahs Quay and Trawsfynydd) are ranked by their capacity for new generation connections; the connected "daughter" infrastructure inherits this rating. The next rating applied is the rating given by SP Manweb for the substation's generation capacity, which is the dominant rating. However in the case where the super station's rating is worse than the generation capacity, the lower rating was used, e.g. Abersoch is rated green for generation by SP Manweb, but feeds into the Trawsfynydd superstation, which has generation constraint at the grid substation level, and hence is rated amber overall.
- 3.6 This resultant RAG rating was used to restrict the number of locations under consideration, given the number of potential Opportunity Areas identified in earlier step; a RAG rating was assigned to each substation to assist in prioritisation.

Connection costs as a proportion of overall project costs

3.7 The financial implications of each Opportunity Areas are assessed in terms of cost of connection and revenue generation potential. SP Energy Networks quote a "high-cost project threshold of £200/kW", which has been taken as an upper limit to connection costs for the proposed Opportunity Areas. There is a detailed methodology⁶ for costing the connection charge for generators (and consumers), however the exact cost of connection varies

⁶ <u>http://www.spenergynetworks.co.uk/userfiles/file/SPEN_connection_methodology.pdf</u>

from site to site depending on factors like the condition of the local grid at the time of the application, what portion of the cost is being borne by the developer and the DNO, the involvement of a third party independent connections provider, or charges due to competition in connection.

- 3.8 The project team sought contact with SP Energy Networks, but without success within the timeframe of this project. Thus detailed connection costs for the proposed Opportunity Areas have not been estimated. The next step will be to apply for a budget estimate from SP Energy Networks in advance of a feasibility study or formal application. Detailed costings would need to be undertaken as part of pre-application viability work by a developer.
- 3.9 It has been assumed that, for larger systems, the connection cost is a smaller proportion of the total project costs than for smaller systems. Hence larger areas of land with lower sensitivity are prioritised, as they have capacity for up to 5MW system, at a lower relative connection cost than a smaller area hosting a smaller system.

Revenue sources

- 3.10 DECC offer a feed-in tariff for standalone PV installations up to 5MW; this is the effective upper size limit for new solar PV farms. The latest published figure for standalone PV is 0.15p/kWh (Jan – Mar 2019)⁷.
- 3.11 Power purchase agreements with developers or utility companies therefore represents the larger contribution to revenue, at around 5p/kWh.

Opportunity Areas

3.12 Within the study area, and taking landscape sensitivity into consideration, **47 Opportunity Areas were identified with potential for development**. To manage the number of Opportunity Areas under consideration, **all sites under 2.4ha were excluded**, i.e. only those able to host 1MW or above were considered. This is because larger capacity solar farms are financially more attractive to developers, as connection costs and other fixed costs represent a smaller proportion of the total cost, and are offset by larger revenue streams. This reduced the list to **38 Opportunity Areas**.

Local Sense Checks

- 3.13 The final step was to undertake a local 'sense check' of the potential areas to ascertain whether there are any further significant constraints in relation to the potential sites.
- 3.14 The table below summarises the residual issues identified within the potential opportunity areas:

Potential Opportunity Area Number	Key Issue
71 Parc Menai	The majority of the potential area includes the garden areas of the Tyn y Lôn Cluster. In light of this, it was removed as a potential area.
4 Mona	Part of the area that falls within the Mona Airfield was removed.
36 Bangor Hospital	The majority of the potential area is a

https://www.ofgem.gov.uk/system/files/docs/2016/04/01_april_2016_tariff_table.pdf

	school playing field. In light of this it was removed as a potential area.
General Issue	A review was undertaken of all the potential sites to ensure that wherever possible individual properties were taken out of the potential area of search. However in certain circumstances due to the shape of the potential area this was not possible.

3.15 With the removal of 71 Parc Menai & 36 Bangor Hospital, the number of potential Opportunity Areas was reduced to 36.

Prioritising the suitable areas

3.16 The full results of the assessment are shown in **Appendix 3**.

Top rated Opportunity Areas

- 3.17 Of the Opportunity Areas identified as having capacity from the Landscape Sensitivity and Capacity Study, only four are in areas without critical grid constraint for generation connections. In order of priority, these are shown in **Table 3.2** and shown on **Map 3.3**.
- 3.18 It is noted that some of these top rated Opportunity Areas are large enough to hold multiple sites. The Areas' boundaries are only indicative and it does not mean all of the land identified within an Opportunity Area would have the benefit of planning consent. It is also important to note that this assessment has also not included a consideration of cumulative impacts which can only be properly assessed at the planning application stage.

Table 3.1 Top rated Opportunity Areas

Site	Substation,	Technical rating and comments	Development size
ID	LA		considerations
35	Parc Menai, Gwynedd	GREEN Connahs Quay – Pentir supergrid; capacity for generation	Landscape Sensitivity Assessment indicates that ≤2.5MW installations may be able to be accommodated; optimal size for solar developer

Site ID	Substation, LA	Technical rating and comments	Development size considerations
5	Rhoslan, Gwynedd	AMBER Trawsfynydd supergrid; less capacity for generation	Landscape Sensitivity Assessment indicates that ≤2.5MW installations may be able to be accommodated; optimal size for solar developer
7	Rhoslan, Gwynedd	AMBER Trawsfynydd supergrid; less capacity for generation	Landscape Sensitivity Assessment indicates that ≤2.5MW installations may be able to be accommodated; optimal size for solar developer
84	Rhoslan, Gwynedd	AMBER Trawsfynydd supergrid; less capacity for generation	Available land limits max installation to ~600kW. Higher proportion of cost of connection, compared to total project cost.

Ranking the remaining Opportunity Areas

3.19 All of the remaining areas 32 are within grid infrastructure that is critically constrained, however in order to prioritise these for consideration within the JLDP, they were ranked as shown in **Table 3.2** and shown on **Map 3.3**. The ranking is based on the sensitivity of the landscape and the size of the potential area available.

Table 3.2 Prioritisation of remaining Opportunity Areas

Constraints on Opportunity Areas	System size	Site ID					
Opportunity Area with area ≥ 12ha with lower landscape sensitivity	5 MW Medium	3, 4, 6, 10, 16, 19, 26, 27, 28					
Opportunity Areas with area ≤12ha with lower landscape	2.5 – 5 MW	34, 37, 39 ⁸					

 $^{^{\}rm 8}$ Site 39 straddles two Landscape Character Areas, and half of the Opportunity Area can be considered more suitable that the other half.


Constraints on Opportunity Areas	System size	Site ID					
sensitivity	Small to medium						
Opportunity Areas with either higher landscape sensitivity or ≤6ha	≤2.5MW Small	42, 45, 47, 53, 56, 57, 58, 59, 2, 9, 20, 22, 23, 32, 50, 51, 52, 60, 61, 62					

- 3.20 Opportunity Areas able to host a 5MW system were prioritised, as the connection costs represent a smaller proportion of the overall costs, and hence have less impact on project viability for a developer.
- 3.21 As referred to in paragraph 3.18, it is noted that the Opportunity Areas identified are often large enough to host multiple sites (up to the capacity dictated by the LSA). However since this assessment has not included a consideration of the cumulative impacts, we have ranked Opportunity Areas based on their ability to host one or more site of the given capacity.


Conclusion

- 3.22 In conclusion, this assessment has identified that there are four top rated opportunity areas with the potential for the development of solar PV farms taking into account of constraints listed in Tables 2.1, 2.3 and 2.4, grid constraints and landscape sensitivity issues. A further 32 areas of opportunity have been identified but which are subject to grid constraints at the present time.
- 3.23 It is recommended that all of the 36 potential areas identified be allocated in the JLDP as areas of search for potential solar PV farm development. **Map 3.3** show the areas it is proposed should be allocated in the JLDP.


3.24 It is important to note that identifying areas of suitability for Solar PV farms does not provide a definitive statement of the suitability of particular location for solar PV. Site specific assessment and design would still be required and all applications would still need to be assessed on their individual merits. The setting of heritage assets, ecology and local landscape issues etc. would need to be carefully considered at a site level. These material planning considerations will be set out in policies in the Joint Local Development Plan.




LA FIG2-1_6823_r1_Study_Area_A3P 30/06/2016




B:KS EB:Manson D LUCGLA FIG2-2_6823_r1_Bu ilt_Up_Areas_and_Infrastructure_A3P 30/06/2016




K LUCGLA FIG2-3_6823_r1_Natural_Features_A3P 30/06/2016





CB:KS EB:Stenson_K LUCGLA FIG2-4_6823_r1_Biodiversity_and_Geodiversity_A3P 30/06/2016







CB:KS EB:Stenson_K LUCGLA FIG2-6_6823_r1_Slope_and_Orientation_A3P 30/06/2016









CB:KS EB:Manson D LUCGLA FIG2-9_6823_r1_012_DNO_Infrastructure_A3P 30/06/2016



Contains Ordnance Survey data © Crown copyright and database right 2016

CB:KS EB:Stenson_K LUCGLA FIG2-10_6823_r1_Landscape_Sensitivity_A3P_30/06/2016






Contains Ordnance Survey data © Crown copyright and database right 2016

CB-KS_EB-Massas D. LIGO

son D LUCGLA FIG3-2_6823_r2_Sensitive_Opp_Areas_A3P 26/07/2016



CB:DM EB:Manson D LUCGLA FIG3-3_6823_r2_Remaining_Opp_Areas_A3P 26/07/2016

Appendix 1 DNO Infrastructure

Description of table heading	S		
Infra type	Category of DNO infrastructure (substation, grid substation, super station)	RAG rated columns	s All these ratings are taken from SP Energy Networks
Parent	Next layer of infrastructure to which this element is connected	Reverse flow	How the local grid will respond to power generation away from substations
Nominal voltage	Rated voltage on this element of the grid	Generation rating	Measure of how much decentralised generation the local grid can tolerate
Group Generation Connected	Total existing capacity of local generation on this region of the network	Fault level	Whether there are faults on the grid around this element; faults often require repairs before local generation can be installed, which adds to the connection cost
Group Generation Contracted	Planned and contracted capacity of local generation on this region of the network	k Wider constraints	Measure of the level of grid constraint elsewhere on the network (notes follow)

DNO infrastructure map - as of 14th June 2016					RAG rating from SPEN heatmap					Subsequent constraints applied Final rating:							
Location Site IDs	Infra type		Parent super	Nominal Ge voltage Co	eneration G onnected C	roup Group eneration firm ontracted capacity MW) (MW)	max [.] y load		Networks overall	Reverse	Generatio rating		Wider	Rating	based on generation rating (substation level)	Notes	Local Authority
			Swansea													Constraint comes from wider 132kV network - Swansea North	
Aberdyfi	Primary substation	Aberystwyth Four Crosses -	North	11		7.50	4.10	1.03	RED	GREEN	GREEN	GREEN	RED	RED	RED	interconnection	Gwynedd
Abersoch	Primary substation		Trawsfynydd	11		4.00	4.08	1.02	RED	AMBER	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd
Alpoco 18, 54	Primary substation	Caergeiliog Amlwch -	Wylfa	11		7.50	2.06	0.51	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Amlwch	Primary substation	Caergeiliog	Wylfa	11		10.00	4.62	1.16	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Amlwch	Grid substation	Four Crosses -	Wylfa	132/33	74.2	106.31 150.00	115.0	028.75	RED		RED	GREEN	RED	RED	RED		Anglesey
Bala	Primary substation	Maentwrog	Trawsfynydd Connahs Quay -	11		4.00	3.58	0.90	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Bangor	Grid substation	Bootle 2A - Burlington	Pentir	132/33	16.07	120.00	115.0	028.75	AMBER		GREEN	AMBER	GREEN	GREEN	GREEN		Gwynedd
23, 36, 60 Bangor Hospital 61, 62), Primary substation	St 1 - Lister	Unknown	11		10.00	7.46	1.87	RED	RED	GREEN	GREEN	RED	RED	RED		Gwynedd
Bangor University	Primary substation	St 1 - Lister	Unknown	11		20.00	13.83	3.46	RED	RED	GREEN	AMBER	RED	RED	RED		Gwynedd
Barmouth	Primary substation		Trawsfynydd	11		4.00	3.67	0.92	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Beaumaris 9, 50, 82	Primary substation	Caergeiliog	Wylfa Connahs Quay -	11		4.00	4.85	1.21	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Bethesda	Primary substation	Caernarfon Four		11		7.50	5.08	1.27	AMBER	GREEN	GREEN	GREEN	AMBER	GREEN	GREEN		Gwynedd
Blaenau Ffestiniog Blanau Plastics	Primary substation Primary substation	Crosses - Maentwrog Four	Trawsfynydd Trawsfynydd			4.00	2.44	0.61	RED RED	AMBER GREEN		GREEN GREEN		AMBER AMBER	AMBER AMBER		Gwynedd Gwynedd

DNO infractruct	turo man - ac	of 14th June 2016									RAG ratir	ng from S	PEN heatn	nap		nt constraints plied		
Location	Site IDs	Infra type	Parent grid station	Parent super	Nominal Ge	eneration Connected C	Generation firm	max y load		Networks overall		Generatio rating	11/33kV n fault level	Wider	Rating based on tssuperstation	Final rating: based on generation rating (substation		Local Authority
	0.00120		Crosses - Maentwrog Four		() ((10.00											
Botwynnog		Primary substation	Four	Trawsfynydd	11		4.00 4.00	3.21	0.80	RED	AMBER	RED	GREEN	RED	AMBER	RED		Gwynedd
Butlins		Primary substation	Crosses - Maentwrog	Trawsfynydd	11		7.50	4.53	1.13	RED	GREEN	AMBER	GREEN	RED	AMBER	AMBER	Substation with most opportunity	
	3, 27, 34, 45, 47, 58, 59, 81, 85,																areas identified LSA: "limited capacity for small -	,
Caergeiliog	87	Primary substation	Caergeiliog	Wylfa	11		7.50	5.39	1.35	RED	GREEN	GREEN	GREEN	RED	RED	RED	medium"	Anglesey
Caergeiliog		Grid substation		Wylfa Connahs	132/33	74.2	106.31 150.00	115.0	028.75	RED		RED	GREEN	RED	RED	RED	PV farm built in this region	Anglesey
Caernarfon		Grid substation		Quay - Pentir	132/33	16.07	120.00	115.0	028.75	AMBER		GREEN	AMBER	GREEN	GREEN	GREEN	(Bontnewydd) - 2014 Prefered	Gwynedd
Caernarfon	24, 33, 74	Primary substation	Bangor - Caernarfon Four	Connahs Quay - Pentir	11		7.50	6.72	1.68	AMBER	GREEN	GREEN	GREEN	AMBER	GREEN	GREEN	substation; but no capacity after LSA	Gwynedd
Carmel		Primary substation		Trawsfynydd	11		2.00 4.00	2.31	0.58	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Cemaes Bay		Primary substation	Amlwch - Caergeiliog	Wylfa	11		4.00	2.95	0.74	RED	AMBER	AMBER	GREEN	RED	RED	RED	Substation located outside survey area,	Anglesey
Cemmaes Roac	ł	Primary substation	Four Crosses - Maentwrog Four	Trawsfynydd	11		2.70 4.00	3.00	0.75	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER	but within 8km of the Gwynedc border	
Cwm Dyli		Primary substation	Four	Trawsfynydd	11		4.00	1.10	0.28	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Dolgellau		Primary substation	Four	Trawsfynydd	11		7.50	4.41	1.10	RED	AMBER	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd
Dyffryn Ardudw	vy	Primary substation	Crosses - Maentwrog Four Crosses -	Trawsfynydd	11		4.00	3.59	0.90	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Edern		Primary substation	Maentwrog Bootle 2A - Burlington	Trawsfynydd	11		4.00	4.37	1.09	RED	AMBER	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd
Eithinog	89	Primary substation	St 1 - Lister Dv 2	Unknown	11		10.00	7.46	1.87	RED	RED	GREEN	GREEN	RED	RED	RED		Gwynedd

Fairbourne Primary substation Aberyster Minor M	DNO infrastruct	ture map - as	of 14th June 2016								RAG ratir	ng from SP	EN heatn	nap		t constraints plied Final rating:		
Fairbourne Primary substation Aberystrykt North- Carnaba 1 4.00 3.11 0.81 ABEP A	Location	Site IDs	Infra type		Parent super	Nominal Genera voltage Connec	ation Generation firm cted Contracted capacit	max :y load	min Ioad	Networks overall	Reverse		nfault	Wider	based on	generation rating (substatior	Notes Constraint	Local Authority
Ferodo Primary substation Caemarfon Cossess- Cossess- Cossess- Cossess- Cossess- Primary substation Pentr Magentrog 11 7.50 3.17 0.79 AMBER AMBER GREEN AMBER AMBER AMBER AMBER AMBER AMBER AMBER AMBER AMBER AMBER AMBER AMBER A	Fairbourne		Primary substation	Aberystwytł	h North	11	4.00	3.31	0.83	RED	AMBER	AMBER	GREEN	RED	RED	RED	wider 132kV network - Swansea North	Gwynedd
Four Crosses Primary substation Magent word Trawsfynydd 11 2.00 4.00 6.20 RED MABER MBER MABER MABER MABER MABER	Ferodo		Primary substation	Caernarfon		11	7.50	3.17	0.79	AMBER	GREEN	GREEN	GREEN	AMBER	GREEN	GREEN		Gwynedd
Gaerwen View 2, 32 Primary substation Amiwch- Gaergeiling Wylfa 1 7.50 2.61 8.ED GREN GREN GREN RED RED RED RED RED RED RED Amber Amber Angles Glan-Yr-Afon Primary substation Maentwrog Trawsfynydd 11 7.50 1.81 0.45 RED GREN GREN RED ABBER AMBER AMBER AMBER Amber Gwynd Harlech Primary substation Maentwrog Trawsfynydd 11 7.50 1.81 0.45 RED GREN GREN GREN RED AMBER AMBER AMBER AMBER AMBER AMBER AMBER AMBER Amber Gwynd Harlech Primary substation Maentwrog Trawsfynydd 11 20.00 13.83 3.46 RED RED RED RED RED RED RED ABER Amber	Four Crosses		Primary substation		Trawsfynydd	11	2.30 4.00	2.62	0.65	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Gaewen View 2, 32 Primary substation Cargeiliog Wylfa 11 7.50 2.61 0.65 RED GREEN GREEN RED RED RED RED RED AMBER Amglese Glan-Yr-Afon Primary substation Primary substation Trawsfynydd 11 7.50 1.81 0.45 RED GREEN GREEN RED AMBER AMBER AMBER Gwyned Harlech Primary substation Maentwrog Trawsfynydd 11 7.50 3.73 0.93 RED GREEN GREEN RED AMBER AMBER AMBER Gwyned Harlech Primary substation Maentwrog Trawsfynydd 11 20.00 13.83 3.46 RED GREEN GREEN RED AMBER <	Four Crosses		Grid substation	A	Trawsfynydd	132/33	82.6 59.20 75.00	115.0	028.75	RED		RED	AMBER	AMBER	AMBER	RED		Gwynedd
Glan-Yr-Afon Primary substation Maentworg Trawsfynydd 11 7.50 1.81 0.45 RED GREEN GREEN RED AMBER AMBER Gwyndd Harlech Primary substation Maentworg Trawsfynydd 11 7.50 1.81 0.45 RED GREEN GREEN RED AMBER AMBER Gwyndd Harlech Primary substation Maentworg Trawsfynydd 11 7.50 1.83 3.46 RED GREEN GREEN RED AMBER AMBER Gwyndd Hirael Primary substation Dv 2 Unknown 11 20.00 1.3.83 3.46 RED RED RED RED RED RED AMBER AMBER Gwyndd Holyhead Primary substation Dv 2 Unknown 11 1.000 9.23 2.31 RED RED<	Gaerwen View	2, 32	Primary substation	Caergeiliog Four	Wylfa	11	7.50	2.61	0.65	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Harlech Primary substation Maentworg bootie 2A - Socie 2A -	Glan-Yr-Afon		Primary substation	Maentwrog Four	Trawsfynydd	11	7.50	1.81	0.45	RED	GREEN	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd
HiraelPrimary substationDv 2 Amlwch - CargeilioUnknown1120.0013.833.46REDREDREDREDREDREDREDREDGREVGREVRED <td>Harlech</td> <td></td> <td>Primary substation</td> <td>Maentwrog Bootle 2A - Burlington</td> <td></td> <td>11</td> <td>7.50</td> <td>3.73</td> <td>0.93</td> <td>RED</td> <td>GREEN</td> <td>GREEN</td> <td>GREEN</td> <td>RED</td> <td>AMBER</td> <td>AMBER</td> <td></td> <td>Gwynedd</td>	Harlech		Primary substation	Maentwrog Bootle 2A - Burlington		11	7.50	3.73	0.93	RED	GREEN	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd
Holyhead Primary substation Caergelion Wlfa 11 10.00 9.23 2.31 RED	Hirael		Primary substation	Dv 2		11	20.00	13.83	3.46	RED	RED	GREEN	AMBER	RED	RED	RED		Gwynedd
55, 63, 73, 88, 90Primary substationAmlwch - Caergelilog Four Conses - MaentwrogWylfa1110.009.232.31REDRE	Holyhead				Wylfa	11	10.00	9.23	2.31	RED	RED	GREEN	GREEN	RED	RED	RED		Anglesey
Lanbedrog Primary substation Maentwrog Trawsfynydd 11 5.00 4.00 3.81 0.95 RED AMBER RED GREEN RED AMBER RE	Llaingoch	55, 63, 73,		Caergeiliog Four	Wylfa	11	10.00	9.23	2.31	RED	RED	GREEN	GREEN	RED	RED	RED	LSA no capacity	Anglesey
Llanberis Primary substation Caernarfon Pentir 11 4.00 3.76 0.94 AMBER AMBER GREEN AMBER GREEN AMBER AMBER GREEN AMBER AMBER GREEN AMBER GREEN AMBER GREEN AMBER AMBER Gwyned Llanddeusant 6, 19 Primary substation Caergeiliog Wylfa 11 7.50 3.81 0.95 RED GREEN GREEN RED RED RED AMDER Anglese	Llanbedrog		Primary substation	Maentwrog	Connahs	11	5.00 4.00	3.81	0.95	RED	AMBER	RED	GREEN	RED	AMBER	RED		Gwynedd
Llanddeusant 6, 19 Primary substation Caergeiliog Wylfa 11 7.50 3.81 0.95 RED GREEN GREEN GREEN RED RED RED Anglese	Llanberis		Primary substation	Caernarfon		11	4.00	3.76	0.94	AMBER	AMBER	AMBER	GREEN	AMBER	GREEN	AMBER		Gwynedd
	Llanddeusant	12, 20, 21,		Caergeiliog	Wylfa	11	7.50	3.81	0.95	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
	Llandegfan			Caergeiliog	Wylfa	11	7.50	2.31	0.58	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Four	Llanfaelog		Primary substation	Caergeiliog Four	Wylfa	11	4.00	3.79	0.95	RED	AMBER	AMBER	GREEN	RED	RED	RED		Anglesey
Crosses - Llanfrothen Primary substation Maentwrog Trawsfynydd 11 4.00 3.21 0.80 RED AMBER AMBER GREEN RED AMBER AMBER AMBER Amlwch -	Llanfrothen		Primary substation	Maentwrog	Trawsfynydd	11	4.00	3.21	0.80	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
	-		-	Caergeiliog	Wylfa	11	7.50	4.91	1.23	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Industrial Estate 76 Primary substation Caergeiliog Wylfa 11 10.00 5.50 1.37 RED GREEN GREEN GREEN RED RED RED Anglese		e 76	Primary substation	Caergeiliog	Wylfa	11	10.00	5.50	1.37	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
	Llangfair PG			Caergeiliog	Wylfa	11	7.50	4.64	1.16	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Amlwch - Llanyfrydog 8, 14, 30 Primary substation Caergeiliog Wylfa 11 4.00 4.15 1.04 RED AMBER GREEN GREEN RED RED RED Anglese	Llanyfrydog	8, 14, 30	Primary substation		Wylfa	11	4.00	4.15	1.04	RED	AMBER	GREEN	GREEN	RED	RED	RED		Anglesey

												RAG rati	ng from SI	PEN heatn	пар		t constraints		
DNO infrastructure	e map - as i Site IDs	of 14th June 2016 Infra type	Parent grid station	Parent superv	Nominal Ge voltage Co	neration G nnected C	eneration firr ontracted car	n r pacity l	max load	load		s Reverse	Generatio	11/33kV	, Wider	Rating	blied Final rating: based on generation rating (substation level)		Local Authority
				Swansea														Substation located outside survey area, but within 8km of the Gwynedd border; constraint comes from wider 132kV network - Swansea North	
Machynlleth		Primary substation	Aberystwyth Four		11		5.3	30 4	4.93	1.23	RED	AMBER	GREEN	GREEN	RED	RED		interconnection	Powys
Maentwrog		Primary substation	Crosses - Maentwrog	Trawsfynydd	11		4.0	00 2	2.38	0.59	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Maentwrog		Grid substation	Four	Trawsfynydd	132/33	82.6	59.20	75 1	115.00)28.75	RED		RED	AMBER	AMBER	AMBER	RED		Gwynedd
Manod		Primary substation	Crosses - Maentwrog Bootle 2A - Burlington St 1 - Lister	Trawsfynydd	11		4.(00 1	1.40	0.35	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
Minffordd		Primary substation	Dv 2 Amlwch -	Unknown	11		20	.00 1	13.83	3.46	RED	RED	GREEN	AMBER	RED	RED	RED		Gwynedd
Mona 4	4, 10, 86	Primary substation	Caergeiliog Amlwch -	Wylfa	11		7.5	50 2	2.06	0.51	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Parc Cybi		Primary substation	Caergeiliog	Connahs	11		10	.00 4	4.16	1.04	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
2	35, 71 29, 38, 64, 65, 68, 72,	Primary substation	Bangor - Caernarfon Bangor -	Quay - Pentir Connahs Quay -	11		7.5	50 2	2.07	0.52	AMBER	GREEN	GREEN	GREEN	AMBER	GREEN	GREEN	LSA allows for	Gwynedd
	75	Primary substation	Caernarfon	Pentir Connahs	11		7.5	50 1	1.50	0.38	AMBER	GREEN	GREEN	GREEN	AMBER	GREEN	GREEN	micro scale only Preferred	Gwynedd
Pentir		Supergrid substation		Quay - Pentir	132	271.56	276.74				AMBER					GREEN		supergrid station	Gwynedd
2	13, 16, 25, 28, 37, 41, 42, 56, 69,		Amlwch -																
	78	Primary substation	Caergeiliog	Connahs	11		7.5	50 5	5.62	1.40	RED	GREEN	GREEN	GREEN	RED	RED	RED		Anglesey
Pen-y-Groes		Primary substation	Four	Quay - Pentir	11		4.(00 3	3.61	0.90	AMBER	AMBER	AMBER	GREEN	AMBER	GREEN	AMBER	PV farm implemented in this region (Llanstumdwy) - 2015; second farm in	Gwynedd
Porthmadog		Primary substation	Four	Trawsfynydd	11		10	.00 5	5.43	1.36	RED	GREEN	GREEN	GREEN	RED	AMBER	AMBER	development 2015	Gwynedd
Pwllheli		Primary substation	Crosses - Maentwrog	Trawsfynydd	11		7.5	50 4	4.57	1.14	RED	AMBER	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd

DNO infrastruc	ture map - as	of 14th June 2016										RAG ratir	ng from SP	EN heatm	ар		t constraints plied Final		
Location	Site IDs	Infra type	Parent grid station	Parent super station	Nominal G voltage Co	eneration onnected	Generation f Contracted c	irm r apacity l	max load		Networks overall	Reverse	Generation rating		Wider	Rating based on superstation	rating: based on generation rating (substation level)		Local Authority
			Amlwch -															Substation with most opportunity areas identified, LSA: "limited capacity for small -	
Raf Valley	1, 39	Primary substation	Caergeiliog Four Crosses -	Wylfa	11		7	2.50	2.51	0.63	RED	GREEN	GREEN	GREEN	RED	RED	RED	medium"	Anglesey
Rhoslan	5, 7, 84	Primary substation		Trawsfynydd	11		7	7.50 <i>4</i>	4.73	1.18	RED	GREEN	GREEN	GREEN	RED	AMBER	AMBER		Gwynedd
Rivals		Primary substation	Maentwrog Bangor -	Trawsfynydd Connahs Quay -	11		4	1.00 2	2.00	0.50	RED	AMBER	AMBER	GREEN	RED	AMBER	AMBER		Gwynedd
St Helen's Road	d 70,91	Primary substation	Caernarfon		11		7	2.50 ²	4.99	1.25	AMBER	GREEN	GREEN	GREEN	AMBER	GREEN	GREEN	Mid-preference supergrid	Gwynedd
Trawsfyndd		Supergrid substation	Four Crosses -	Trawsfynydd	132	82.19	64.20				AMBER					AMBER	AMBER	station	Gwynedd
Tryweryn		Primary substation		Trawsfynydd	11		4	1.00 (0.85	0.21	RED	AMBER	RED	GREEN	RED	AMBER	RED	Constraint comes from wider 132kV network - Swansea North interconnection PV farm built	Gwynedd
Tywyn		Primary substation	Aberystwyth	Connahs	11		7	2.50 <i>4</i>	4.71	1.18	RED	AMBER	GREEN	GREEN	RED	RED	RED	here (Tywyn) 2015	Gwynedd
Waenfawr	15, 17, 44, 67, 77	Primary substation	Bangor - Caernarfon	Quay - Pentir	11		7	7.50	3.87	0.97	AMBER	AMBER	GREEN	GREEN	AMBER	GREEN	GREEN	Least preferred	Gwynedd
Wylfa		Supergrid substation		Wylfa	132	71.39	106.31				RED					RED	RED	supergrid station	Anglesey

Appendix 2

Landscape Sensitivity and Capacity Review

Summary of Isle of Anglesey, Gwynedd and Snowdonia National Park: Landscape Sensitivity and Capacity Assessment (March 2014)

Anglesey

LCA Code	Solar PV Sensitivity	Notes from Landscape Sensitivity and Capacity Study
A1	∨н	Typically no capacity for field-scale solar PV energy developments within this LCA.
A2	MH	N/A
A3	н	N/A
A4	VH	N/A
		Outside the AONB and SLA it is considered there may be some capacity for micro to small scale developments, in particular where these would relate well to the existing built environment/urban landcover.
A5	м	There may also be limited capacity for very infrequent sensitively sited small to medium scale development towards the south of the LCA.
A6	м	Within the AONB and SLAs (and all areas that contribute to their setting), there is typically no capacity for field-scale solar PV energy developments. Outside the AONB and SLAs it is considered there may be some capacity for well sited micro to small scale developments, in particular where these may relate to the existing built environment/urban landcover.
A7	Н	N/A
A8	МН	Sensitivity increases within the parts of this LCA that fall within the Anglesey AONB and the distinctive Parciau Estatelands SLA as these areas are more tranquil, remote and scenic. The AONB is focussed towards the east along the coast and the prominent landform of Mynydd Bodafon and is largely free from energy and other modern developments (with the exception of some static caravan/chalet parks). Outside the AONB and SLAs it is considered there may be some capacity for micro scale developments, in particular where these may relate to the existing built environment/urban landcover.
		The villages, together with the established road network, high number of static caravans and existing wind turbines and telecommunication masts have an influence on the character of the landscape and diminish the sense of remoteness and tranquillity in places, therefore reducing the sensitivity field scale solar PV development.
A9	м	Outside the AONB there may be limited capacity for micro scale developments, in particular where these relate well to the existing built environment/urban landcover.
A10	н	N/A

LCA Code	Solar PV Sensitivity	Notes from Landscape Sensitivity and Capacity Study
		Sensitivity is enhanced by many sensitive visual receptors and intervisibility and associations with important landscape and cultural heritage features including the National Park, Beaumaris Castle - Castles and Town Walls of King Edward in Gwynedd World Heritage Site and Anglesey AONB.
A11	мн	Typically no capacity for field-scale solar PV energy developments within this LCA.
		Outside the AONB and SLAs it is considered there may be some capacity for well sited micro to small scale developments, in particular where these may relate to the existing built environment/urban landcover. Sensitivity is further increased by the value of this landscape as a setting to the Anglesey AONB together with a high cultural heritage value as recognised through a number of historic designations (such as Penmon Registered Historic Landscape and Registered Parks and
A12	M	Gardens) increases the overall sensitivity.
A13	Н	N/A
A14	Н	N/A
		Transport infrastructure influences the north of the LCA thus locally reducing the sensitivity. However this is outweighed by the remoteness and tranquillity experienced in other areas of the landscape as reflected by the designation of the regional Malltraeth Marsh & Surrounds SLA and parts of this landscape designated within the Anglesey AONB which together with the cultural heritage value of the landscape further enhances sensitivity.
A15	МН	Typically no capacity for field-scale solar PV energy developments within this LCA.
A16	М	N/A
		Within the AONB and SLAs (and all areas that contribute to their setting), there is typically no capacity for field-scale solar PV energy (with the exception of very infrequent micro scale, development)
		The Mona airfield and A5/A55 corridor detract from the tranquillity of the landscape, further reducing sensitivity.
A17	LM	There may also be limited capacity for larger scale developments, in particular towards the south west where the landscape is already influenced by modern infrastructure.
		The RAF Valley Airfield brings a level of visual intrusion to the area. The flat landform away from the coast comprises medium to large scale field systems enclosed by a mixture of boundaries including hedgerows which introduce the possibility of increasing vegetation height to provide further localised screening and therefore lessen sensitivity to field-scale solar PV energy development.
A18	М	Outside the AONB and SLAs it is considered there may be some capacity for well sited micro scale developments, in particular where these may relate to the existing built environment/urban landcover.

Gwynedd

LCA	Solar PV Sensitivity	Notes from Landscape Sensitivity and Capacity Study
		Field systems are typically medium in scale and regular in pattern with a mix of field boundaries lessening the sensitivity of the landscape to field-scale solar PV energy development.
		This is counterbalanced by the presence of a high number of sensitive visual receptors in some places, nationally designated cycle routes and nationally important Registered Historic Landscapes together with a high degree of intervisibility from important landscape and cultural heritage features (including the National Park, Anglesey AONB and Beaumaris Castle - Castles and Town Walls of King Edward in Gwynedd World Heritage Site).
		Within all areas that contribute to the setting of the National Park, there is typically no capacity for field-scale solar PV energy developments. However, outside these areas there may be some limited capacity for field-scale solar PV energy developments. This could typically comprise occasional, well sited micro to small scale developments.
G01	м	Lavan Sands is particularly tranquil and devoid of man-made influence, therefore sensitivity in this locality is considered higher.
G02	МН	N/A
		The sensitivity of the landscape is reflected in the fact that much of the LCA is regionally designated as a Special Landscape Area and almost the entire area lies within nationally important Registered Historic Landscapes.
G03	МН	Within the SLA (and all areas that contribute to its setting and the setting of the National Park), there is typically no capacity for field- scale solar PV energy developments. Outside these areas there may be limited capacity for well sited micro scale developments.
		Field systems vary in scale and pattern throughout the area as do field boundaries; the least sensitive areas in terms of field scale and pattern are located towards the coast in the west where interviewing blocks of woodland and tree belts are more frequent and may provide opportunities for screening.
		Within the AONB and SLAs (and all areas that contribute to their setting and the setting of the National Park and WHS), there is typically no capacity for fieldscale solar PV energy developments.
G04	м	Outside these areas there may be limited capacity for well sited micro scale developments.
G05	МН	N/A
G06	VH	N/A
G07	Н	N/A
		This medium scale, low lying coastal plain landscape comprises a mosaic of rural landcover interspersed with modern coastal resort developments. These resorts, together with major road and rail infrastructure strongly influence the character of the landscape and diminish the sense of remoteness and tranquillity, thus reducing sensitivity to field-scale solar PV energy development.
G08	M	Within all areas that contribute to the setting of the SLAs and the National Park, there is typically no capacity for field-scale solar PV energy developments. However, outside these areas there may be some limited capacity for very infrequent well-sited and micro scale field-scale solar PV energy developments.

LCA	Solar PV Sensitivity	Notes from Landscape Sensitivity and Capacity Study
G09	МН	N/A
		There are some large coniferous plantation to the north of the LCA and existing 400 kV overhead lines punctuate the skyline to the far east which further reduces sensitivity. Nevertheless, this is a relatively tranquil landscape with man-made influence otherwise limited to scattered rural properties and villages, connected by a network of local roads. Sensitivity is enhanced in places by the value placed on parts of the landscape which lie within the Llŷn AONB and Lleyn and Bardsey
		Island Registered Historic Landscape, together with the presence of some sensitive receptors.
G10	М	Outside the SLAs/AONBs/setting of the National Park there may be limited capacity for well sited micro to small scale developments.
G11	MH	N/A
G12	MH	N/A
G13	Н	N/A
G14	Н	N/A
G15	М	N/A

Appendix 3 Full Assessment Results

Description of table headers	
Site ID	Unique site identifier from GIS assessment
Substation	Nearest grid infrastructure (see appendix 1)
Area	Total area within the opportunity area
LSA comments	Comments taken directly from the review of the Landscape Sensitivity Assessment
LCA	Landscape Character Area
Max system size allowable from LSA	If comments reference a system size (micro, small, medium), this determines size of the system permissible within the oppo
Total potential capacity from area	Total power capacity possible if whole area were covered with solar PV; often much larger than allowable by LSA
Total annual energy output	Energy generated per year from this size of system
No. household equivalent energy consumption	Metric used by DECC when evaluating energy systems; number of households this amount of energy would supply
Worst case scenario connection cost	Maximum cost of connection of the maximum system size within this opportunity area
Annual FiT	Revenue earned per year from government subsidies, if this system connected before March 2018
Potential annual Power Purchase Agreement or Export earnings	Revenue earned per year from sale of power to the grid or a utility company
5	

Substation (RAG rating = final Site_ID rating from tech assessment)	Area (ha) Landscape Sensitivity Assessment comments	LCA		Total potential capacity from area (MW)	Total annual energy output (MWh)	No. household equivalent energy consumption	Worst case scenario connection cost (within LSA threshold)	Annual FiT	Potential annual Power Purchase Agreement/Export earnings
1 RAF Valley	200.68 Limited capacity for micro scale	A18	0.50	83.62	73,298	22,212 f	100,000 £	657	£ 21,915
2 Gaerwen View	137.60 Some capacity for micro to small-scale	A12	2.50	57.33	50,258	15,230 f	500,000 £	3,287	£ 109,575
3 Caergeiliog	Limited capacity for small to medium scale 115.00 development	A5/A1	.8 5.00	47.92	42,004	12,728 f	£ 1,000,000 £	6,575	£ 219,150
4 Mona	54.90 Some capacity	A17	5.00	22.88	20,052	6,076 f	1,000,000 £	6,575	£ 219,150
5 Rhoslan	117.30 Some capacity for micro to small-scale	G8/G1	10 2.50	48.88	42,844	12,983 f	500,000 £	3,287	£ 109,575
6 Llanddeusant	Limited capacity for small to medium scale 126.70 development	A5	5.00	52.79	46,277	14,023 f	1,000,000 £	6,575	£ 219,150
7 Rhoslan	90.90 Some capacity for micro to small-scale	G10	2.50	37.88	33,201	10,061 f	500,000 £	3,287	£ 109,575
8 Llanyfrydog	79.85 Some potential for micro scale development	A8	0.50	33.27	29,165				
9 Beaumaris	72.00 Some capacity for micro to small-scale	A12	2.50	30.00	26,298	7,969 f	500,000 £	3,287	£ 109,575
10 Mona	44.10 Some capacity	A17	5.00	18.38	16,108	4,881 f	1,000,000 £	6,575	£ 219,150
11 Llaingoch	40.52 No capacity	A1	-	16.88	14,800				
12 Llandegfan	35.72 No capacity	A11	-	14.88	13,047				
13 Pentraeth	29.90 Limited capacity for micro scale	A9		12.46	10,921				

portunity area

for reference for reference for reference for reference for reference for reference

Substation (RAG rating = final Site_ID rating from tech assessment)	Area (ha) Landscape Sensitivity Assessment comments	LCA	Max system size allowable from LSA (MW) 0.50	Total potential capacity from area (MW)	Total annual energy output (MWh)	No. household equivalent energy consumption	Worst case scenario connection cost (within LSA threshold)
14 Llanyfrydog	26.90 Some potential for micro scale development	A8	0.50	11.21	9,825		
15 Waenfawr	26.51 Some capacity for development <1ha	A3	0.50	11.05	9,683		
16 Pentraeth	27.00 Some capacity	A17	5.00	11.25	9,862	2,988 f	1,000,000 £
17 Waenfawr	24.05 Some capacity for development <1ha	G3	0.50	10.02	8,784		
19 Llanddeusant	Limited capacity for small to medium scale 19.30 development	A5	5.00	8.04	7,049	2,136 f	1,000,000 £
20 Llandegfan	22.30 Some capacity for micro to small-scale	A12	2.50	9.29	8,145	2,468 f	500,000 £
21 Llandegfan	19.87 No capacity	A11	-	8.28	7,258		
22 Llangfair PG	14.70 Some capacity for micro to small-scale	A12	2.50	6.13	5,369	1,627 f	500,000 £
23 Bangor Hospital	16.30 Some capacity for micro to small-scale	G1	2.50	6.79	5,954	1,804 f	500,000 £
24 Caernarfon	15.59 Some capacity for micro-scale	G4	0.50	6.50	5,694		
25 Pentraeth	15.26 Limited capacity for micro scale	A9	0.50	6.36	5,574		
26 Llangefni	14.40 Some capacity	A17	5.00	6.00	5,260	1,594 f	1,000,000 £
27 Caergeiliog	Limited capacity for small to medium scale 12.30 development	A5	5.00	5.13	4,493	1,361 f	1,000,000 £
28 Pentraeth	13.20 Some capacity	A17	5.00	5.50	4,821	1,461 f	1,000,000 £
29 Peblic Mills	11.86 Some capacity for micro-scale	G4	0.50	4.94	4,332		
30 Llanyfrydog	11.42 Some potential for micro scale development	A8	0.50	4.76	4,171		
31 Llaingoch	10.01 No capacity	A1	-	4.17	3,656		
32 Gaerwen View	6.50 Some capacity for micro to small-scale	A12		2.71	2,374	719 f	500,000 £

Annual FiT

6,575	£	219,150

- 6,575 £ 219,150
- 3,287 £ 109,575
- 3,287 £ 109,575
- 3,287 £ 109,575

- 6,575 £ 219,150
- 6,575 £ 219,150
- 6,575 £ 219,150

3,287 £ 109,575

Substation (RAG rating = final Site_ID rating from tech assessment)	Area (ha) Landscape Sensitivity Assessment comments	LCA		Total potential capacity from area (MW)	Total annual energy output (MWh)	No. household equivalent energy consumption	Worst case scenario connection cost (within LSA threshold)
33 Caernarfon	8.56 Some capacity for micro-scale	G4	0.50	3.57	3,127		
34 Caergeiliog	Limited capacity for small to medium scale 7.40 development	A5	5.00	3.08	2,703	819 f	6,654,167 £
35 Parc Menai	5.70 Some capacity for micro to small-scale	G1	2.50	2.38	2,082	631 f	951,667 £
37 Pentraeth	7.40 Some capacity	A17	5.00	3.08	2,703	819 f	2 71,667 £
38 Peblic Mills	7.31 Some capacity for micro-scale	G4	0.50	3.05	2,670		
39 RAF Valley	Limited capacity for small to medium scale 6.40 development	A5/A1	8 5.00	2.67	2,338	708 f	9,583,333 £
40 Llangefni Industrial Estate	6.91 No capacity	A15	-	2.88	2,524		
41 Pentraeth	6.10 Limited capacity for micro scale	A9	0.50	2.54	2,228		
42 Pentraeth	5.70 Some capacity	A17	5.00	2.38	2,082	631 f	1,608,333 £
43 Llangefni Industrial Estate	5.69 No capacity	A15	-	2.37	2,078		
44 Waenfawr	5.66 Some capacity for development <1ha	G3	0.50	2.36	2,067		
45 Caergeiliog	Limited capacity for small to medium scale 4.00 development	A5	5.00	1.67	1,461	443 f	6,000,000 £
46 Llaingoch	5.52 No capacity	A1	-	2.30	2,016		
47 Caergeiliog	Limited capacity for small to medium scale 5.00 development	A5	5.00	2.08	1,826	553 f	3,675,000 £
48 Llandegfan	5.27 No capacity	A11	-	2.20			
49 Llandegfan	5.16 No capacity	A11	-	2.15	1,885		
50 Beaumaris	4.40 Some capacity for micro to small-scale	A12	2.50	1.83	1,607	487 f	533,333 £
51 Llangfair PG	5.10 Some capacity for micro to small-scale	A12	2.50	2.13	1,863	564 f	713,333 £

	Potential annual
	Power Purchase
	Agreement/Export
Annual FiT	earnings

- 43,748 £ 135,143
- 6,257 £ 104,096
- 471 £ 135,143
- 63,006 £ 116,880

10,574 £ 104,096

- 39,447 £ 73,050
- 24,161 £ 91,313
- 3,506 £ 80,355
- 4,690 £ 93,139

Substation (RAG rating = final Site_ID rating from tech assessment)	Area (ha) Landscape Sensitivity Assessment comments	LCA		Total potential capacity from area (MW)	Total annual energy output (MWh)	No. household equivalent energy consumption	Norst case scenario connection cost (within LSA threshold)
52 Llangfair PG	3.50 Some capacity for micro to small-scale	A12	2.50	1.46	1,278	387 £	616,667 £
53 Llangfair PG	2.80 Some capacity	A17	5.00	1.17	1,023	310 £	1,200,000 £
54 Alpoco	2.78 No capacity	A1	-	1.16	1,015		
55 Llaingoch	4.63 No capacity	A1	-	1.93	1,691		
56 Pentraeth	4.40 Some capacity	A17	5.00	1.83	1,607	487 £	1,858,333 f
57 Llangefni	4.20 Some capacity	A17	5.00	1.75	1,534	465 £	1,100,000 £
58 Caergeiliog	Limited capacity for small to medium scale 4.10 development	A5	5.00	1.71	1,498	454 £	3,376,667 £
59 Caergeiliog	Limited capacity for small to medium scale 2.30 development	A5	5.00	0.96	840	255 £	2,976,667 £
60 Bangor Hospital	2.80 Some capacity for micro to small-scale	G1	2.50	1.17	1,023	310 £	416,667 £
61 Bangor Hospital	4.00 Some capacity for micro to small-scale	G1	2.50	1.67	1,461	443 £	439,167 £
62 Bangor Hospital	2.60 Some capacity for micro to small-scale	G1	2.50	1.08	950	288 £	430,000 £
63 Llaingoch	2.55 No capacity	A1	-	1.06	931		
64 Peblic Mills	2.52 Some capacity for micro-scale	G4	0.50	1.05	920		
65 Peblic Mills	2.49 Some capacity for micro-scale	G4	0.50	1.04	909		
66 Llangefni Industrial Estate	2.43 No capacity	A15	-	1.01	888		
67 Waenfawr	2.39 Some capacity for development <1ha	G3	0.50	1.00	873		
68 Peblic Mills	2.20 Some capacity for micro-scale	G4	0.50	0.92	804		
69 Pentraeth	2.19 Some capacity	A17	5.00	0.91	800	242 £	1,655,833 £
70 St Helen's Road	2.05 Some capacity for micro-scale	G4	0.50	0.85	749		

Annual FiT	Potential a Power Purc Agreement/ earning	chase Export
4,054	£	63,919
7,889	£	51,135
12,218	£	80,355
7,232	£	76,703
22,200	£	74,876
19,570	£	42,004
2,739	£	51,135
2,887	£	73,050
2,827	£	47,483

Substation (RAG rating = final Site_ID rating from tech assessment)	Area (ha) Landscape Sensitivity Assessment comments	LCA	Max system size allowable from LSA (MW)	Total potential capacity from area (MW)	Total annual energy output (MWh)	No. household equivalent energy consumption	Vorst case scenario connection cost (within LSA threshold)
72 Peblic Mills	1.96 Some capacity for micro-scale	G4	0.50	0.82	716		
73 Llaingoch	1.92 No capacity	A1	-	0.80	701		
74 Caernarfon	1.91 Some capacity for micro-scale	G4	0.50	0.80	698		
75 Peblic Mills	1.90 Some capacity for micro-scale	G4	0.50	0.79	694		
76 Llangefni	1.90 Some capacity	A17	5.00	0.79	694	210 £	988,333 £
77 Waenfawr	1.87 Some capacity for development <1ha	G3	0.50	0.78	683		
78 Pentraeth	1.86 Some capacity	A17	5.00	0.78	679	206 £	1,225,000 £
79 Llandegfan	1.73 No capacity	A11	-	0.72	632		
80 St Helen's Road	1.73 Some capacity for micro-scale	G4	0.50	0.72	632		
81 Caergeiliog	Limited capacity for small to medium scale 1.70 development	A5	5.00	0.71	621	188 £	2,491,667 £
82 Beaumaris	1.65 Some capacity for micro to small-scale	A12	2.50	0.69	603	183 £	575,833 £
83 Llandegfan	1.54 No capacity	A11	-	0.64	562		
84 Rhoslan	1.50 Some capacity for micro to small-scale	G10	2.50	0.63	548	166 £	474,167 £
85 Caergeiliog	Limited capacity for small to medium scale 1.49 development	A5	5.00	0.62	544	165 £	2,241,667 £
86 Mona	1.45 Some capacity	A17	5.00	0.60	530	160 £	1,271,667 £
87 Caergeiliog	Limited capacity for small to medium scale 1.36 development	A5	5.00	0.57	497	151 £	2,209,167 £
88 Llaingoch	1.36 No capacity	A1	-	0.57	497		
89 Eithinog	1.35 Some capacity for micro to small-scale	G1	2.50	0.56	493	149 £	471,667 £
90 Llaingoch	1.28 No capacity	A1	-	0.53	468		

Potential annual Power Purchase Agreement/Export earnings

Annual FiT

6,498	£	34,699

8,054 £ 33,968

16,381 f 31,046

3,786 £ 30,133

3,117 £ 27,394

14,738 £ 27,211

8,361 £ 26,481

14,524 £ 24,837

3,101 £ 24,654

Site_ID	Substation (RAG rating = final rating from tech assessment)	Area (ha) Landscape Sensitivity Assessment comments	LCA	Max system size allowable from LSA (MW)	Total potential capacity from area (MW)	Total annual energy output (MWh)	No. household equivalent energy consumption	Worst case scenario connection cost (within LSA threshold)
91	St Helen's Road	1.23 Some capacity for micro-scale	G4	0.50	0.51	449		
92	Llaingoch	3.31 No capacity	A1	-	1.38	1,209		
93	Llaingoch	2.60 No capacity	A1	-	1.08	950		

Кеу	
GREEN	Technical capacity within local grid; preferred location for new generation connections
AMBER	Some technical capacity within local grid; mid-priority location for new generation connections
RED	Minimal technical capacity within local grid; least preferred location for new generation connections
GREY	No potential for solar PV, or only micro systems possible

Calculation assumptions

DECC solar PV data

2.4 ha/MW

1MW 0.1 capacity factor

- 8766 hours per year
- 3.3 MWhpa Annual consumption per household

Grid connection costs

£50,000/MW	Max value for viable project (solar developer research)
£200/kW	Maximum cost from National Grid

Revenue generation

0.15p/kWhStand alone solar PV FiT Q4 2018https://www.ofgem.gov.uk/system/files/docs/2016/04/01_april_2016_tariff_table.pdf4.91p/kWhExport tariff Q4 2018https://www.ofgem.gov.uk/system/files/docs/2016/04/01_april_2016_tariff_table.pdf5.00p/kWhTypical PPA ratehttp://www.sunedison.co.uk/residential-and-commercial-ppa.html

Potential annual Power Purchase Agreement/Export earnings

Annual FiT